

**2013 WATER QUALITY TABLE
MEMPHIS LIGHT, GAS, AND WATER**

ANALYTES PRIMARY STANDARDS - MANDATORY HEALTH-RELATED STANDARDS	MAXIMUM CONTAMINANT LEVEL	SHEAHAN STATION	ALLEN STATION	MCCORD STATION	MALLORY STATION	LICHTERMAN STATION	DAVIS STATION	MORTON STATION	PALMER STATION	LNG PLANT	SHAW STATION	AVERAGE FOR
												ALL TREATMENT PLANTS
CLARITY												
TURBIDITY (NTU)	2.0	0.13	0.16	0.25	0.63	0.14	0.22	0.18	0.10	0.08	0.12	0.20
MICROBIOLOGICAL												
TOTAL COLIFORM (Colonies/100 mL)	(a)	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
FECAL COLIFORM (Colonies/100 mL)	(a)	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
ORGANIC CHEMICALS (mg/L)												
PESTICIDES*												
ALACHLOR	0.002	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
ATRAZINE	0.003	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CHLORDANE	0.002	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
ENDRIN	0.002	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
HEPTACHLOR	0.0004	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
HEPTACHLOR EPOXIDE	0.0002	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
LINDANE	0.0002	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
METHOXYCHLOR	0.04	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
POLYCHLORINATED BIPHENYLS (PCB'S)	0.0005	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
SIMAZINE	0.004	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TOXAPHENE	0.003	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
SEMI-VOLATILE ORGANIC COMPOUNDS*												
BENZO(a)-PYRENE	0.0002	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
DI(2-ETHYLHEXYL) ADIPATE	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
DI(2-ETHYLHEXYL) PHTHALATE	0.006	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
HEXACHLOROENBENZENE	0.001	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
HEXACHLOROCYCLOPENTADIENE	0.05	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
VOLATILE ORGANIC COMPOUNDS*												
BENZENE	0.005	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CARBON TETRACHLORIDE	0.005	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-DICHLOROENBENZENE	0.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,4-DICHLOROENBENZENE	0.075	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-DICHLOROETHANE	0.005	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1-DICHLOROETHYLENE	0.007	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CIS-1,2-DICHLOROETHYLENE	0.07	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TRANS-1,2-DICHLOROETHYLENE	0.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
DICHLOROMETHANE	0.005	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-DICHLOROPROPANE	0.005	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
ETHYLBENZENE	0.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
MONOCHLOROENBENZENE	0.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
STYRENE	0.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TETRACHLOROETHYLENE	0.005	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TOLUENE	1.0	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,1-TRICHLOROETHANE	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,2-TRICHLOROETHANE	0.005	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TRICHLOROETHYLENE	0.005	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-TRICHLOROENBENZENE	0.07	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
VINYL CHLORIDE	0.002	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TOTAL XYLENES	10.0	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TOTAL TRIHALOMETHANES	0.080	0.005	0.012	0.003	0.004	0.006	ND	0.012	0.011	0.012	0.001	0.007
INORGANIC CHEMICALS (mg/L)												
ALUMINUM *	0.2	0.003	0.017	0.010	0.005	0.015	0.150	0.027	0.009	0.007	0.019	0.026
ANTIMONY *	0.006	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
ARSENIC *	0.01	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
BARIUM *	2.0	0.033	0.050	0.031	0.043	0.018	0.067	0.064	0.027	0.020	0.012	0.037
BERYLLIUM *	0.004	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CADMIUM *	0.005	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CHROMIUM *	0.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
COPPER *	1.3**	0.002	0.015	0.003	0.001	0.004	0.004	0.004	0.03	0.013	0.003	0.008
LEAD *	0.015**	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
MANGANESE *	0.05	0.002	0.008	0.004	0.006	0.003	0.004	0.002	0.007	0.011	0.003	0.005
MERCURY	0.002	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
NICKEL *	0.1	ND	ND	ND	ND	ND	ND	ND	0.003	ND	ND	ND
POTASSIUM*	NS	0.51	0.57	0.63	0.53	0.39	0.79	0.78	0.82	0.79	0.44	0.63
SILVER *	0.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
SELENIUM *	0.05	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
THALLIUM *	0.002	0.0010	0.0008	0.0008	0.0008	0.0008	0.0010	0.0009	0.0009	0.0009	0.001	0.0009
ZINC *	5.00	0.0008	0.0008	0.0007	0.0006	0.0028	0.0030	0.0005	0.0200	0.0020	0.0005	0.0032
CHEMICAL PARAMETERS												
CHLORIDE (mg/L)	250	2.7	4.6	4.0	2.2	4.3	3.6	2.0	2.9	2.5	3.6	3.2
COLOR * (units - PCS)	15	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5
CYANIDE (mg/L)	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
DETERGENTS - MBAS (mg/L)	0.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
FLUORIDE (mg/L)	4.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
IRON (mg/L)	0.3	0.05	0.03	0.06	0.05	0.03	0.03	0.02	0.02	0.02	0.02	0.03
NITRATE (as Nitrogen) (mg/L)	10.0	ND	ND	ND	ND	0.26	ND	ND	ND	ND	ND	ND
NITRITE (as Nitrogen) (mg/L)	1.0	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
ODOR (TON)	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
pH (units)	6.5 - 8.5	7.1	7.2	7.2	7.2	7.1	7.3	7.2	7.1	7.1	7.2	7.2
SODIUM* (mg/L)	NS	6.8	9.0	8.7	7.6	7.3	7.6	5.8	6.9	6.5	5.6	6.1
SPECIFIC CONDUCTANCE (umho/cm @ 25°C)	X900	112	153	126	137	91	229	137	98	87	86	124
SULFATE (mg/L)	250	16.2	21.6	17.6	15.8	15.1	14.7	9.5	3.9	21.8	21.1	15.7
TOTAL DISSOLVED SOLIDS *(mg/L)	500	66	91	72	71	63	115	66	64	76	50	73
ADDITIONAL PARAMETERS												
ALKALINITY as CaCO3 (mg/L)	NS	44	66	47	66	35	117	61	40	34	20	53
CALCIUM (mg/L)	NS	6.7	10.9	7.8	10.5	5.4	20.1	11.1	4.4	5.7	2.7	8.5
HARDNESS as CaCO3 (mg/L)	NS	38	60	42	54	30	108	53	31	30	17	46
HARDNESS (grains/gal)	NS	2.2	3.5	2.5	3.2	1.8	6.3	3.1	1.8	1.8	1.0	2.7
MAGNESIUM (mg/L)	NS	5.2	8.0	5.5	6.7	4.0	14.0	6.1	4.9	3.8	2.5	6.1
PHOSPHATE (mg/L)	NS	1.2	1.1	1.2	1.2	1.3	15.3	1.2	1.3	1.5	1.2	1.3
TEMPERATURE (*C)	NS	20.1	18.3	18.6	19.9	19.3	18.3	18.7	20.2	18.9	19.1	19.1
TEMPERATURE (*F)	NS	68.2	64.9	65.5	67.8	66.7	64.9	65.7	68.4	66.0	66.4	66.5
TOTAL ORGANIC CARBON* (mg/L)	NS	0.383	0.495	0.398	0.476	0.339	0.636	0.421	0.290	0.289	0.205	0.393

KEY TO ABBREVIATIONS

NTU = Nephelometric Turbidity Units, a measure of the suspended material in water.

(a) = No more than 5.0% of the monthly samples may be total-coliform positive.

< = Less Than

mg/L = Milligrams Per Liter (parts per million)

ND = Below Method Detection Limit

* Sample analysis was not required in 2013. Shown is most recent data collected.

umho/cm = Micromhos per centimeter

X = Recommended Level

NS = No Standard

PCS = Platinum-Cobalt Standard

TON = Threshold Odor Number

** = Action Level. The Federal and State standards for lead and copper are treatment techniques requiring agencies to optimize corrosion control treatment.